



ETL Verified Certificate of Conformance Number: 103291226CRT-001

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out.

Rendered to:

3C3 India Pvt Ltd

Ujjni Pegasus, No. 1557, 2nd Floor, 8th Cross


Chandra Layout

Bangalore, Karnataka - 560 040, India

Contact: Mr. Sunil Kumer M

Product Tested:

3-Connector Permanent Link



<u>Component ID</u>	<u>Manufacturer</u>	<u>Part Number</u>	<u>Description</u>
1	3C3 India	12319 / 118D0	Keystone Jack / Patch Panel
2	3C3 India	103DE	Horizontal Cable, 85 m
3	3C3 India	2B3D0-XXXX	Equipment Cord, 5 m

Standard(s)/Specification: ANSI/TIA-568.2-D Category 6A and ISO/IEC 11801-1 Class E_A with the applicable electrical transmission characteristics

Product(s) Literature May Include: ETL Verified 3-Connector Permanent Link to ANSI/TIA-568.2-D Category 6A and ISO/IEC 11801-1 Class E_A, along with permanent link illustration, and parts numbers.

Continuing compliance to this specification is monitored through production testing, ongoing inspections by Intertek at the production facility and random sample testing.

Date Issued: November 02, 2017

Date Revised: September 29, 2020

Approved By:

Antoine Pelletier, Project Engineer

This verification supersedes all previous verifications with the noted Verification/Report number(s) dated before this verification notice.

NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.